

Energy performance certificate (EPC)

46 BEECH AVENUE ANDERTON PR6 9PQ	Energy rating	Valid until:	14 February 2031
	E	Certificate number:	4300-5751-0922-8094-3293

Property type **Detached bungalow**

Total floor area **85 square metres**

Rules on letting this property

Properties can be let if they have an energy rating from A to E.

You can read [guidance for landlords on the regulations and exemptions](https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance) (<https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance>).

Energy rating and score

This property's energy rating is E. It has the potential to be C.

[See how to improve this property's energy efficiency.](#)

Score	Energy rating	Current	Potential
92+	A		
81-91	B		
69-80	C		78 C
55-68	D		
39-54	E	51 E	
21-38	F		
1-20	G		

The graph shows this property's current and potential energy rating.

Properties get a rating from A (best) to G (worst) and a score. The better the rating and score, the lower your energy bills are likely to be.

For properties in England and Wales:

the average energy rating is D
the average energy score is 60

Breakdown of property's energy performance

Features in this property

Features get a rating from very good to very poor, based on how energy efficient they are. Ratings are not based on how well features work or their condition.

Assumed ratings are based on the property's age and type. They are used for features the assessor could not inspect.

Feature	Description	Rating
Wall	Cavity wall, filled cavity	Average
Roof	Pitched, 100 mm loft insulation	Average
Window	Fully double glazed	Average
Main heating	Boiler and radiators, oil	Average
Main heating control	Programmer and room thermostat	Average
Hot water	From main system	Average
Lighting	Low energy lighting in 56% of fixed outlets	Good
Floor	Solid, no insulation (assumed)	N/A
Secondary heating	Room heaters, electric	N/A

Primary energy use

The primary energy use for this property per year is 265 kilowatt hours per square metre (kWh/m²).

How this affects your energy bills

An average household would need to spend **£1,029 per year on heating, hot water and lighting** in this property. These costs usually make up the majority of your energy bills.

You could **save £320 per year** if you complete the suggested steps for improving this property's energy rating.

This is **based on average costs in 2021** when this EPC was created. People living at the property may use different amounts of energy for heating, hot water and lighting.

Heating this property

Estimated energy needed in this property is:

- 11,138 kWh per year for heating
- 2,841 kWh per year for hot water

Impact on the environment

This property produces 5.5 tonnes of CO₂

This property's environmental impact rating is E. It has the potential to be C.

This property's potential production 2.8 tonnes of CO₂

Properties get a rating from A (best) to G (worst) on how much carbon dioxide (CO₂) they produce each year.

You could improve this property's CO₂ emissions by making the suggested changes. This will help to protect the environment.

Carbon emissions

An average household produces 6 tonnes of CO₂

These ratings are based on assumptions about average occupancy and energy use. People living at the property may use different amounts of energy.

Changes you could make

Step	Typical installation cost	Typical yearly saving
1. Increase loft insulation to 270 mm	£100 - £350	£61
2. Floor insulation (solid floor)	£4,000 - £6,000	£104
3. Low energy lighting	£20	£26
4. Heating controls (TRVs)	£350 - £450	£36
5. Condensing boiler	£2,200 - £3,000	£51
6. Solar water heating	£4,000 - £6,000	£42

Step	Typical installation cost	Typical yearly saving
7. Solar photovoltaic panels	£3,500 - £5,500	£312

Help paying for energy improvements

You might be able to get a grant from the [Boiler Upgrade Scheme \(https://www.gov.uk/apply-boiler-upgrade-scheme\)](https://www.gov.uk/apply-boiler-upgrade-scheme). This will help you buy a more efficient, low carbon heating system for this property.

More ways to save energy

Find ways to save energy in your home by visiting www.gov.uk/improve-energy-efficiency

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Clive Golding
Telephone	01204 494 924
Email	torridon05@btinternet.com

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Elmhurst Energy Systems Ltd
Assessor's ID	EES/015789
Telephone	01455 883 250
Email	enquiries@elmhurstenergy.co.uk

About this assessment

Assessor's declaration	No related party
Date of assessment	15 February 2021
Date of certificate	15 February 2021
Type of assessment	RdSAP
