Energy performance certificate (EPC)

13 Leyburn Road LONDON N18 2BG	Energy rating **D**	Valid until:	**15 December 2031**
		Certificate number:	**9503-2769-0202-0192-0592**

Property type	End-terrace house
Total floor area	97 square metres

Rules on letting this property


Properties can be let if they have an energy rating from A to E.

You can read guidance for landlords on the regulations and exemptions (https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance).

Energy rating and score

This property's energy rating is D. It has the potential to be B.

See how to improve this property's energy efficiency.



The graph shows this property's current and potential energy rating.

Properties get a rating from A (best) to G (worst) and a score. The better the rating and score, the lower your energy bills are likely to be.

For properties in England and Wales:

- the average energy rating is D
- the average energy score is 60

Breakdown of property's energy performance

Features in this property

Features get a rating from very good to very poor, based on how energy efficient they are. Ratings are not based on how well features work or their condition.

Assumed ratings are based on the property's age and type. They are used for features the assessor could not inspect.

Feature	Description	Rating
Wall	Solid brick, as built, no insulation (assumed)	Very poor
Roof	Pitched, 12 mm loft insulation	Very poor
Roof	Flat, no insulation (assumed)	Very poor
Window	Fully double glazed	Average
Main heating	Boiler and radiators, mains gas	Good
Main heating control	Programmer, TRVs and bypass	Average
Hot water	From main system	Good

Feature	Description	Rating
Lighting	Low energy lighting in 56% of fixed outlets	Good
Floor	Suspended, no insulation (assumed)	N/A
Floor	Solid, no insulation (assumed)	N/A
Floor	To unheated space, no insulation (assumed)	N/A
Secondary heating	None	N/A

Primary energy use

The primary energy use for this property per year is 289 kilowatt hours per square metre (kWh/m2).

▶ About primary energy use

How this affects your energy bills

An average household would need to spend **£1,026 per year on heating, hot water and lighting** in this property. These costs usually make up the majority of your energy bills.

You could **save £485 per year** if you complete the suggested steps for improving this property's energy rating.

This is **based on average costs in 2021** when this EPC was created. People living at the property may use different amounts of energy for heating, hot water and lighting.

Heating this property

Estimated energy needed in this property is:

- 15,525 kWh per year for heating
- 2,221 kWh per year for hot water

Impact on the environment

This property's environmental impact rating is E. It has the potential to be B.

Properties get a rating from A (best) to G (worst) on how much carbon dioxide (CO2) they produce each year.

Carbon emissions

An average household produces	6 tonnes of CO2
This property produces	4.9 tonnes of CO2
This property's potential production	1.3 tonnes of CO2

You could improve this property's CO2 emissions by making the suggested changes. This will help to protect the environment.

These ratings are based on assumptions about average occupancy and energy use. People living at the property may use different amounts of energy.

Steps you could take to save energy

▶ Do I need to follow these steps in order?

Step 1: Increase loft insulation to 270 mm

Typical installation cost	£100 - £350
Typical yearly saving	£65
Potential rating after completing step 1	**58 D**

Step 2: Flat roof or sloping ceiling insulation

Typical installation cost	£850 - £1,500
Typical yearly saving	£68
Potential rating after completing steps 1 and 2	**61 D**

Step 3: Internal wall insulation

Typical installation cost	£4,000 - £14,000
Typical yearly saving	£217
Potential rating after completing steps 1 to 3	**71 C**

Step 4: Floor insulation (suspended floor)

Typical installation cost	£800 - £1,200
Typical yearly saving	£51
Potential rating after completing steps 1 to 4	**73 C**

Step 5: Low energy lighting

Typical installation cost	£20
Typical yearly saving	£30
Potential rating after completing steps 1 to 5	**74 C**

Step 6: Heating controls (room thermostat)

Typical installation cost	£350 - £450
Typical yearly saving	£23
Potential rating after completing steps 1 to 6	**75 C**

Step 7: Solar water heating

Typical installation cost	£4,000 - £6,000
Typical yearly saving	£30
Potential rating after completing steps 1 to 7	**76 C**

Step 8: Solar photovoltaic panels, 2.5 kWp

Typical installation cost	£3,500 - £5,500
Typical yearly saving	£347
Potential rating after completing steps 1 to 8	**86 B**

Advice on making energy saving improvements

Get detailed recommendations and cost estimates

Help paying for energy saving improvements

You may be eligible for help with the cost of improvements:

- Free energy saving improvements: Warm Homes Local Grant (WHLG)
- Heat pumps and biomass boilers: Boiler Upgrade Scheme
- Help from your energy supplier: Energy Company Obligation

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Christopher Christophorou
Telephone	07984740407
Email	chris@ecologicltd.co.uk

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Quidos Limited
Assessor's ID	QUID201064
Telephone	01225 667 570
Email	info@quidos.co.uk

About this assessment

Assessor's declaration	No related party
Date of assessment	15 December 2021
Date of certificate	16 December 2021
Type of assessment	▶ RdSAP

Other certificates for this property

If you are aware of previous certificates for this property and they are not listed here, please contact us at mhclg.digital-services@communities.gov.uk or call our helpdesk on 020 3829 0748 (Monday to Friday, 9am to 5pm).

Certificate number	9358-1949-6229-8189-2954 (/energy-certificate/9358-1949-6229-8189-2954)
Expired on	14 November 2021

Certificate number	8905-0298-2829-7496-1393 (/energy-certificate/8905-0298-2829-7496-1393)
Expired on	10 July 2021

Help (/help) Accessibility (/accessibility-statement) Cookies (/cookies)
Give feedback (https://forms.office.com/e/KX25htGMX5)
Service performance (/service-performance)

OGL
All content is available under the Open Government Licence v3.0 (https://www.nationalarchives.gov.uk/doc/open-government-licence/version/3/), except where otherwise stated

© Crown copyright (https://www.nationalarchives.gov.uk/information-management/re-using-public-sector-information/uk-government-licensing-framework/crown-copyright/)